

PIMPRI CHINCHWAD NEW TOWN DEVELOPMENT AUTHORITY, AKURDI, PUNE- 411 044.

Name of Work : Construction of 20 MVA 22/11 KV- Electrical Substation, along with Allied Electrical HT Infrastructure work at Sector 12

Tender Notice No. Elect/04 for 2019-2020

Prebid Meeting Date : 27/08/2019 @ 15.00 hrs

Common Set of Clarification / Deviation


Sl	Tender Clause	Clarification required by bidder	Clarification / Deviation
1	Cl. 4.3 (m), Pg 8 Bidders should have Electrical Contractor License issued by I.E.& L Deptt. and Registered Electrical Contractor Class "A" or above issued by Public Works Electrical Deptt. Government of Maharashtra	With respect to above subject we are interested to participate in the above referred tender. Whereas you have asked for "Registered Electrical Contractor Class "A" Government of Maharashtra" vide point no. 4.3(m) whereas as per point no. 2.9.1 of Government of Maharashtra Resolution dated 12 April 2017 and point no. 6b of resolution dated 29 June 2017, A class contractor license is not required enclosed Government of Maharashtra Resolution for works above 1.5 crores. Hence your good selves are requested to delete the above referred point.	Bidders should have Electrical Contractor License issued by I.E.& L Deptt. Government of Maharashtra
2		The Tender is Called for National competitive bidding & you have asked for "Registered Electrical Contractor Class "A" issued by Public works Electrical Department, GOM, vide point no 4.3m. We request your Good selves , kindly revise the qualification point to "Registered Electrical contractor Class "A" issued by Electrical dept of any state from India.	Please Refer Sr.No-01 of CSC/CSD
3		In the above said work tender we request you to modify 5MVA Transformer two numbers instead of one 10 MVA Transformer.	NIT Prevails
4		It is understood that, this project needs to be executed under the supervision of MSEDCL and handed over to MSEDCL and hence all the materials and equipments for this work should be from any	NIT Prevails

SI	Tender Clause	Clarification required by bidder	Clarification / Deviation
		MSEDCL Infra II approved make. This will ease the process for the inspection, Testing, Commissioning and Handing over to MSEDCL procedures. So kindly incorporate same in the Tender.	
5		The majority of work included in this tender are for installation and commissioning of bought out items. So to maintaining the cash flow, kindly change payment terms as <ul style="list-style-type: none"> • Against supply of materials - 80% • After Erection - 10% • After Commissioning - 5% After Handing over to MSEDCL - 5%	NIT Prevails
6		The Existing Bhosari division, MIDC, Sector 12 is 22KV system but we have constructed 22/11KV substation, but at a time handover to this substation it's intricate	NIT Prevails
7		The Substation 11KV Outgoing feeder's cable length & 11KV Teak of structure not mentioned in scope or tender.	NIT Prevails
8		The 22KV incomer 15 km cable digging or excavation RI charges payment details not cleared.	<p>Presently charges against digging or excavation of road for laying of cable are not applicable to PCNTDA.</p> <p>However it is the responsibility of the bidder to make application, to do all liasoning with the local body prior to start such activity, as this is incidental to the work.</p> <p>During the excavation along the road it is the responsibility of the bidder to ensure all precautionary measures, safety barricade, safety sign boards are in place to avoid any misshaping during the activity and to ensure no inconvenience is caused to any public by way of the activity carried out by the bidder directly or indirectly, In case during the excavation if the bidder damages any of the utilities laid, then it is the responsibility of the bidder to reinstate the services within 24 Hrs of such breakdown</p>

SI	Tender Clause	Clarification required by bidder	Clarification / Deviation
9		<p>"Bidders should have Electrical Contractor License issued by I.E. & L Dept. And Registered Electrical Contractor Class "A" issued by Public Works Electrical Dept. Government of Maharashtra" vide point no. 4.3(m).</p> <p>kindly revise the qualification point to "Bidders should have Electrical Contractor License issued by I.E. & L Dept. And Registered Electrical Contractor Class "A" or above issued by Electrical Dept. of any states from India</p>	Please Refer Sr. No-01 of CSC/CSD
10		<p>The makes of items must be of MSEDCL approved makes only. Accordingly, please incorporate all MSEDCL approved makes for the materials required for this work.</p> <p>For Power Transformer; 1) M/s. Trans Fab Power (India) Pvt. Ltd</p> <p>For Vacuum Circuit Breaker; 1) M/s. Popular Switchgear Pvt. Ltd 2) M/s. Power Control Electro System Pvt. Ltd.</p>	NIT Prevails

[Handwritten Signature]

Consultant



[Handwritten Signature]
AAO

[Handwritten Signature]
Dy. Engineer-~~UI~~(Elect)
Deputy Engineer (Elect),
Division No. 6

[Handwritten Signature]
Executive Engineer / S.E.
EXECUTIVE ENGINEER (Elec)
Pimpri Chinchwad New Town
Development Authority
Nigdi, Pune - 411 044.

[Handwritten Signature]
C.A.F.O.
[Handwritten Initials]

[Handwritten Signature]
C.E.O.